

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. SPL-01

Date: 16-06-2026

It is certified that an inspection team headed by KASHISH BARRAR (Junior Engineer)
(Name of Officers
with designation) from Water Supply & Sanitation Sub div. Malout (Name of
Department/Office) inspected the Newton World School
Malout (Name & Address of
the School) on 10-06-2026 and found that the Newton World
School (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 31-03-2027.

Signature with Seal : [Signature]
Name : W/S & Sanitation Sub Division
Designation : Malout
Sub Divisional Engineer
Sub div. Malout

To
Principal
Newton World School
Malout
(Name & Address of the Institution)

BLOCK WATER TESTING LABORATORY, MALOUT

Water Supply & Sanitation Sub Division 3, BSNL Exchange Road, Malout
blwtlmalout@gmail.com

TEST REPORT


Name & Address of Customer : Principal, Newton World School Newton World School, Malout		Customer Reference No.	No : NWS/ADM/26-27/01 Dated : 14/05/2026
		Sample Submitted by	Kashmir Singh
		Date of Sample Receipt	19/05/2026
		Analysis Starting Date	19/05/2026
		Analysis completion Date	20/05/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC000126000000118F	Sample Type :	Treated Water
Test Report No.:	BWTL/MLT/2627/00100	Date of Issue :	20/05/2026
Registration no.:	BWTL/MLT/REG2627/00198	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Transparent Plastic Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Newton World School, Malout / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Muktsar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.21	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	TDS	120	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
5	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
6	T. Alkalinity(CaCO ₃)	30	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
7	T. Hardness(CaCO ₃)	52	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
8	Calcium(Ca)	11	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
9	Magnesium(Mg)	6	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
10	Chloride(Cl)	20	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For,Block Water Testing Laboratory
Malout

End of the Test Report

BLOCK WATER TESTING LABORATORY, MALOUT

Water Supply & Sanitation Sub Division 3, BSNL Exchange Road, Malout
blwtlmalout@gmail.com

To,

Principal, Newton World School
Newton World School, Malout


No.: BWTL/MLT/2627/00100 Dated : 20/05/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. NWS/ADM/26-27/01 Dated: 14/05/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 19/05/2026. It is request to fill the attached feedback form and send it back to Block Water Testing Laboratory, Malout

D/A : Test Report



Authorized Signatory
For, Block Water Testing Laboratory
Malout